

Aussenstelle Erwitte • Auf den Thränen 2 • 59597 Erwitte • Telefon (02943) 897-0 • Telefax (02943) 897 33 • E-Mail: erwitte@mpanrw.de

CONFIRMATION OF CLASSIFICATION

no. 231000908

Producer

CELO Befestigungssysteme GmbH

Industriestraße 6 86551 Aichach

Building product

"DSH-M / DSH-T"

Produkt description:

Mechanical fixing system for insulation products

made of non-coated galvanized steel

Classification:

The above mentioned material is classified as

Class A1 ("no contribution to fire") according to DIN EN 13501-1

correspondent to decision 96/603/EG of the European Commission of 04.10.1996.

This confirmation of classification written in English language is issued additionally to the confirmation of classification written in German language with the same number. In case of doubt the German version is valid solely.

Erwitte, 27.07.2020

On behalf

Dipl.-Ing. Schreiner

Assistant head of testing body



Publishing and copying of this classification certificate without permission of the MPA NRW is only allowed without any changes of the content and the form of the certificate. The shortened reproduction of the classification certificate needs the permission of the MPA NRW.

This classification certificate consists of 1 page.